


NOTES:

- 1. GAS PIPING AND FITTINGS SHALL BE STANDARD WEIGHT BLACK IRON PIPE.
- 2. SLEEVE AND FITTINGS SHALL BE SCHEDULE 40 PVC.
- 3. LOCATION AND PLACEMENT SHALL ALLOW FOR READY REMOVAL.
- 4. ACCESS PANEL SHALL BE SIZED AND LOCATED TO ALLOW FOR READY REMOVAL OF COUPLINGS AND VERTICAL PIPE EXTENSIONS.
- 5. TWO AIR PRESSURE TESTS ARE REQUIRED AND SHALL BE OF 5 PSI AND HOLD FOR 15 MINUTES.
 - A. AFTER PLACEMENT OF SLEEVE AND PRIOR TO ENCASEMENT.
 - B. AT THE TIME OF FINAL INSPECTION WITH PIPING INSTALLED.
- 6. SLEEVE SHALL BE GRADES TO VENT TO ATMOSPHERE.



BELOW SLAB INSTALLATION GAS PIPING

BUILDING DEPARTMENT

Scale: 1 "= 1 '-0".

Date: SEPTEMBER 2001

Sheet: 1 of 1 Sheets

Drawn By; KSL Checked By: —